



# 2009 E2S2 Symposium

## Designing, Integrating, and Operating a Microgrid 07 May, 2009

Clark B. Boriack, Manager  
Power Management and Distribution

Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE <b>07 MAY 2009</b>		2. REPORT TYPE		3. DATES COVERED <b>00-00-2009 to 00-00-2009</b>	
4. TITLE AND SUBTITLE <b>Designing, Integrating, and Operating a Microgrid</b>				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) <b>Concurrent Technologies Corporation,Power Management Distribution,100 CTC Drive,Johnstown,PA,15904</b>				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT <b>Approved for public release; distribution unlimited</b>					
13. SUPPLEMENTARY NOTES <b>Presented at the NDIA Environment, Energy Security &amp; Sustainability (E2S2) Symposium &amp; Exhibition held 4-7 May 2009 in Denver, CO. U.S. Government or Federal Rights License</b>					
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT <b>Same as Report (SAR)</b>	18. NUMBER OF PAGES <b>27</b>	19a. NAME OF RESPONSIBLE PERSON
a. REPORT <b>unclassified</b>	b. ABSTRACT <b>unclassified</b>	c. THIS PAGE <b>unclassified</b>			

# Outline

- Microgrid Definition
- Microgrid Benefits
- Testbed Requirements
- Technical Approach
- Results

# What is a Microgrid?

## General Definition:

- A microgrid is an integrated energy system consisting of interconnected loads and distributed energy resources that can operate in parallel with the grid or in an intentional island mode.


## Key Defining Characteristics:

- Integrated distributed energy resources (DERs), capable of providing sufficient and continuous energy to mission critical loads
- Independent controls; island and reconnect with minimal disruption
- Flexible configuration and operation of the power delivery system
- Optimized local DERs, large network loads, and broader power system

# What a Microgrid is NOT

- One microturbine in a commercial building
- A group of individual generation sources that are not coordinated, but run optimally for a narrowly defined load
- A load or group of loads that cannot be easily separated from the grid or controlled
- A system that can only operate in isolation from the grid
- Does not have to have thermal (whereas CHP by definition has thermal)

# Microgrid Overview



# Microgrid Potential Benefits

- IMPROVED RELIABILITY
  - Critical load support
  - Integration of multiple generation sources (legacy and renewable)
- RISK MITIGATION
  - Eliminate dependence upon local utility
  - Integrating available energy sources for backup power
- ELECTRICAL COST REDUCTION
  - Intelligent control for peak shaving
  - Renewable Energy Integration
  - Improved asset utilization by integrating distributed sources

# Microgrid Testbed Objective

- Objective – Design, install, and test a scalable microgrid with distributed generation sources and loads
  1. Modeling and Simulation – Software tool to confirm design strategies and solutions
  2. System Controllers – Combination Distribution Management System and Internet resource
  3. Renewable Energy Sources – Combined generation of conventional generation with renewable energy sources.



# Microgrid Testbed Requirements

- Improve System Reliability
  - Eliminate single points of failure by using redundant controls
  - Intelligently control sources to meet load requirements
  - Intelligently control loads to avoid system overloads
  - Develop software modeling to predict system limitations and develop appropriate controls
  - Simplify generator synchronization controls by using one controller as opposed to three independent relays (typical scheme)
  - Integrate IEE1547 intertie relay for parallel operation with the utility
  - COTS parts for quick support, replacement

# Microgrid Testbed Requirements

- Benefit from System Modeling
  - Develop software models to simulate component and system performance to identify performance limitations and control solutions
  - Use developed models to design and implement future microgrids or improve existing systems
- Improve Asset Utilization
  - Integrate distributed sources and loads into one distribution system to allow for efficient use of generation assets
  - Improving asset utilization reduces fuel consumption and associated logistics requirements
  - Integrate renewable sources as available


# Microgrid Approach

- Microgrid Master and Local Controllers
  - Programmable Logic Controllers (PLCs) to coordinate and implement intelligent control of distributed sources and loads.
  - Redundant controllers to avoid single points of failure.
  - LabView based-HMI to provide oversight and configure testing
  - COTS components
- Generator Controls
  - One main controller per generator simplifies synchronization of conventional generation sources compared to configuring and integrating three additional control relays per generator.
  - COTS components

# Microgrid Approach

- Software Modeling -
  - Prepare software models of individual sources and loads to predict impact to electrical system.
  - Create a microgrid system model from the individual component models to predict system performance.
  - Validate accuracy and correct simulation models
  - Create test cases and control strategies based upon system performance/limitations predicted and validated by models.
- Control Algorithms –
  - Monitor system health and intelligently control sources and loads
  - Coordinated control between controllers for system stability

# System One-line



# Distributed Sources and Loads

- Distributed Sources
  - (1) 35 kW Diesel Generator
  - (1) 35 kW Natural Gas Generator
  - (1) 40kW Renewable Energy Inverter
  - (1) 400A Utility Service
  - (1) 50kW Grid Simulator
- Distributed Loads
  - (4) 5 hp three phase motors
  - (1) 20hp dynamometer
  - (1) 225 kW Resistive Load Bank



# Test Plan

- Component Model Validation
  - (1) 35 kW Diesel Generator
  - (1) 35 kW Natural Gas Generator
  - (1) 40kW Renewable Energy Inverter
  - (1) 50kW Grid Simulator
  - (4) 5 hp three phase motors
  - (1) 20hp dynamometer
  - (1) 225 kW Resistive Load Bank
- System Model Validation and Analysis
- System Stability Testing and Analysis

# Test Results Summary


## Steady State Accuracy: 90+%

Test	Description	Real Power % Accuracy	Reactive Power % Accuracy
TC1-1	RLB Component Validation Test	>91% (steady state at load bus)	N/A
TC1-2	MLB Component Validation Test	N/A	>95% (steady state at load bus)
TC1-3	20 hp Motor w/ Dynamometer Component Validation Test	>95% (steady state at load bus)	>90% (steady state at load bus)
TC1-4	Inverter Component Validation Test	>99% (steady state at inverter bus)	N/A
TC1-5	DG Component Validation Test	>92% (steady state at load bus)	>90% (steady state at load bus)
TC1-6	NGG Component Validation Test	>92% (steady state at load bus)	>90% (steady state at load bus)
TC2-1	Grid-connected System Validation Test	>97% (steady state at load bus)	>92% (steady state at load bus)




# Dyno Component Test One-line

## Connected: Utility, 20Hp Dynamometer



# Dyno Component Test Results


## Model kW vs Actual - 95+% Accurate



# Dyno Component Test Results


**Note: Identify System Stress Points, VAR Requirements**

TC1-3 Load Bus Total Reactive Power



# Inverter Component Test One-Line


## Connected: Utility, Inverter



# Inverter Component Test Results

## Initial Model kW vs Actual -


**Note: False Output Ringing Predicted by Model**



# Inverter Component Test Results


## Revised Model kW vs Actual

**Note: Model Configuration Impacts Simulation Software Results**



# System Test One-line


Connected: Utility, Gensets, Inverter, RLB, MLB, Dyno



# System Test Results

## Utility Current THD Measurements

Note: Confirm THD






# System Test Results

## Utility Neutral Current Measurements

Note: Confirm Neutral Current Direction



# System Test Results

## Note: Neutral Current Solutions

- Transformer Isolation
  - Delta-Wye Transformer traps 3<sup>rd</sup> order harmonics
- Three Phase Harmonic Filter
  - Wye – Delta Transformer to eliminate zero sequence currents
- Neutral Reactor
  - Tuned reactor to block 3<sup>rd</sup> order currents only
- Neutral Grounding
  - Establish one neutral path to ground
  - Confirm neutral grounding when isolated from utility

# Acknowledgements

- ERDC-CERL Contract No.
  - W9132T-07-R-0017
- ERDC-CERL Technical Monitor – Frank Holcomb  
(217) 373-5864  
[Franklin.H.Holcomb@erdc.usace.army.mil](mailto:Franklin.H.Holcomb@erdc.usace.army.mil)

# Contact Information

Clark Boriack

Concurrent Technologies Corporation

Manager, Power Management Distribution

(814) 262-2381

Email: [boriackc@ctc.com](mailto:boriackc@ctc.com)

Web Address: <http://www.ctc.com>